

し尿処理の状況及び放流水質の推移

2024年3月 末現在

	投入量	放流量	希釈水 (井戸水)	脱水汚泥	電力使用量	放流水質(平均)				
						BOD(mg/L)	COD(kg/日)	全窒素(kg/日)	全りん(kg/日)	pH
	(kL)	(kL)	(kL)	(kg)	(kWh)	<10mg/L	<21.45kg/日	<28.6kg/日	<1.43kg/日	6.0~8.0
R5.4	7,275.0	29,356.0	24,348.0	166,140.0	191,606.0	0.3	5.033	1.252	0.007	6.9
R5.5	6,793.3	30,106.0	25,606.0	171,980.0	198,871.0	0.4	4.990	1.399	0.013	6.9
R5.6	6,982.4	29,129.0	24,202.0	163,930.0	183,836.0	0.2	5.138	1.044	0.017	6.9
R5.7	7,074.0	30,841.0	25,548.0	171,800.0	196,537.0	0.9	5.329	0.793	0.034	6.8
R5.8	6,366.8	28,765.0	24,157.0	98,070.0	182,274.0	0.6	5.177	0.570	0.080	6.8
R5.9	6,331.4	28,163.0	23,575.0	105,680.0	184,670.0	1.0	4.986	0.848	0.109	6.8
R5.10	6,793.3	30,618.0	25,812.0	130,320.0	179,338.0	0.5	4.294	0.038	0.807	7.0
R5.11	6,756.8	29,885.0	24,997.0	164,710.0	175,312.0	0.4	4.281	0.015	0.596	6.9
R5.12	7,056.8	32,499.0	27,723.0	155,100.0	188,159.0	0.1	4.491	0.009	0.349	6.9
R6.1	5,974.8	25,509.0	22,119.0	133,740.0	174,866.0	0.3	3.954	0.252	0.023	7.0
R6.2	6,734.8	27,801.0	22,137.0	184,750.0	179,964.0	0.1	4.408	0.026	0.096	7.0
R6.3	7,222.7	31,533.0	25,225.0	177,530.0	202,914.0	0.2	4.860	0.685	0.024	6.9
令和5年度	81,362.1	354,205	295,449	1,823,750	2,238,347	0.4	4.745	0.578	0.180	6.90
令和4年度	83,147.4	350,276	304,983	2,000,590	2,388,481	0.4	4.654	1.074	0.015	6.81
令和3年度	86,499.0	353,161	345,963	1,917,200	2,368,265	0.6	4.892	0.822	0.038	6.84
令和2年度	74,613.3	513,055	455,829	1,656,070	2,276,952	0.7	6.821	2.697	0.032	6.83

泉佐野市田尻町清掃施設組合